



- CEILING NOTES**
- ALL CEILING HEIGHTS ARE 9'-0" AFF UNLESS NOTED OTHERWISE.
 - REFER TO ELECTRICAL DRAWINGS FOR ALL EMERGENCY LIGHTING NOT SHOWN.
 - COORDINATE LAYOUT OF LAY-IN CEILING GRID WITH AS-BUILT DIMENSION OF SPACE. VERIFY LAYOUT WITH ARCHITECT. DO NOT USE PIECES OF TILE LESS THAN 4" IN WIDTH.
 - SUPPORT GRID FROM STRUCTURAL MEMBERS. SUPPORT LIGHT FIXTURES ON FOUR CORNERS DIRECTLY TO STRUCTURE. DO NOT SUPPORT GRID OR EQUIPMENT FROM ROOF DECK.
 - SEE DETAIL 6 FOR TYPICAL CEILING EDGE DETAIL.
 - COORDINATE LOCATION OF MECHANICAL, ELECTRICAL AND SPRINKLERS IN CEILING.
 - MODIFY EXIST. CEILING AS REQUIRED FOR ROUTING OF ELECTRICAL CONDUIT AND PIPING TRANSITIONS. PROVIDE DROPPED SOFFIT WHERE NEEDED. REPAIR OR EXIST. CEILING TILES AND GRID DAMAGED DURING CONSTRUCTION.
 - WHERE SUFFICIENT SPACE EXISTS ABOVE EXISTING CEILINGS, ALL SPRINKLER PIPING SHALL BE RUN ABOVE CEILINGS. WHERE PIPING MUST BE RUN EXPOSED IN FINISHED SPACES, IT SHALL BE PAINTED.
 - PROVIDE FIRE SUPPRESSION SPRINKLER SYSTEM THROUGHOUT. COORDINATE HEAD LOCATION WITH CEILING HEIGHT AND MECHANICAL AND ELECTRICAL WORK. ALL PIPING IS TO BE ABOVE CEILINGS AND IN WALLS IN FINISHED SPACES. IF EXPOSED PIPING IS REQUIRED FOR DRAINS AND CHECK DEVICES, IT SHALL BE RUN IN STORAGE OR UTILITY SPACES AND SHALL BE PAINTED.
- ALL CEILING AND DEVICES INDICATED IN CEILING ARE NEW U.N.O.
- 2' x 4' LAY-IN ACOUSTICAL TILE IN SUSPENDED METAL GRID
 - 2' x 4' RECESSED FLOURESCENT LIGHTING FIXTURE
 - 1' x 4' SUSPENDED FLOURESCENT LIGHTING FIXTURE
 - CEILING MOUNTED EXIT LIGHT
 - INDICATES 6" ACOUSTICAL INSULATION ABOVE CEILING
 - CEILING MOUNTED SPEAKER
 - EXHAUST FAN
 - 2' x 2' SUPPLY DIFFUSER
 - EXHAUST DIFFUSER
 - CEILING HEATER - SEE MECHANICAL

FILE: N:\CCSD\MISC-10\HARRISON.MEDIA PRODUCTION\DRAWINGS\HARRISON.MEDIA FLOOR PLAN.DWG - PLOTTED: 11 JUN 10 10:48AM